

SV and SVH Spiral Diffusers USV, USVH Universal Spiral Diffusers (Page 38)

See page 39 for min. duct diameter.

Face Velocity		300	400	500	600	700	800	1000	1200
Total Pressure		.016	.029	.046	.066	.090	.117	.183	.263
10 x 3 Ak .14	CFM	42	56	70	84	98	112	140	168
	Horizontal Throw	7-3	8-4	9-5	10-6	11-7	12-8	13-9	14-10
	Noise Criteria	-	-	-	-	-	23	29	35
12 x 3 Ak .18	CFM	54	72	90	108	126	144	180	216
	Horizontal Throw	8-5	9-6	10-7	11-8	12-8	13-9	14-10	16-11
	Noise Criteria	-	-	-	-	20	24	31	36
10 x 4 14 x 3 Ak .21	CFM	63	84	105	126	147	168	210	252
	Horizontal Throw	8-5	10-7	11-8	12-8	13-9	14-10	16-11	17-12
	Noise Criteria	-	-	-	-	21	25	31	37
16 x 3 12 x 4 Ak .25	CFM	75	100	125	150	175	200	250	300
	Horizontal Throw	9-5	11-7	12-8	13-9	14-10	15-11	17-12	19-13
	Noise Criteria	-	-	-	-	21	25	32	37
24 x 3 12 x 6 Ak .39	CFM	117	156	195	234	273	312	390	468
	Horizontal Throw	12-7	13-9	15-10	17-11	18-12	19-13	21-15	24-16
	Noise Criteria	-	-	-	-	23	27	34	39
24 x 4 16 x 6 Ak .52	CFM	156	208	260	312	364	416	520	624
	Horizontal Throw	13-8	16-11	18-12	19-13	21-14	22-15	25-17	27-19
	Noise Criteria	-	-	-	20	24	28	35	40
14 x 8 18 x 6 Ak .63	CFM	189	252	315	378	441	504	630	756
	Horizontal Throw	15-8	17-12	19-13	21-14	23-16	24-17	27-19	30-20
	Noise Criteria	-	-	-	20	25	29	36	41
20 x 6 Ak .66	CFM	198	264	330	396	462	528	660	792
	Horizontal Throw	15-9	18-12	20-13	22-15	24-16	25-17	28-19	31-21
	Noise Criteria	-	-	-	21	25	29	36	41
16 x 8 Ak .71	CFM	213	284	355	426	497	568	710	852
	Horizontal Throw	16-9	18-13	20-14	23-15	24-17	26-18	30-20	35-22
	Noise Criteria	-	-	-	21	26	30	36	42
24 x 6 18 x 8 Ak .88	CFM	264	352	440	528	616	704	880	1056
	Horizontal Throw	18-10	20-14	23-16	25-17	27-18	29-20	32-22	36-24
	Noise Criteria	-	-	-	22	26	30	37	43
20 x 8 16 x 10 Ak .98	CFM	294	392	490	588	686	784	980	1176
	Horizontal Throw	19-10	21-15	24-17	26-18	28-19	30-21	34-23	38-25
	Noise Criteria	-	-	-	23	27	31	38	44
18 x 10 Ak 1.11	CFM	333	444	555	666	777	888	1110	1332
	Horizontal Throw	20-11	23-16	25-18	28-19	30-21	32-22	36-25	40-27
	Noise Criteria	-	-	-	23	27	31	38	44
36 x 6 18 x 12 Ak 1.35	CFM	405	540	675	810	945	1080	1350	1620
	Horizontal Throw	22-12	25-17	28-19	31-21	34-23	36-24	40-27	44-30
	Noise Criteria	-	-	-	24	28	32	39	44
24 x 10 20 x 12 Ak 1.49	CFM	447	596	745	894	1043	1192	1490	1788
	Horizontal Throw	23-13	26-18	30-20	32-22	35-24	37-26	42-29	46-31
	Noise Criteria	-	-	-	24	29	33	39	45
24 x 12 Ak 1.82	CFM	546	728	910	1092	1274	1456	1820	2184
	Horizontal Throw	25-14	30-20	33-22	36-25	39-27	42-28	47-32	51-35
	Noise Criteria	-	-	-	25	30	34	40	46
36 x 10 30 x 12 Ak 2.29	CFM	687	916	1145	1374	1603	1832	2290	2748
	Horizontal Throw	29-16	33-22	37-25	41-28	44-30	47-32	53-36	61-42
	Noise Criteria	-	-	20	26	30	34	41	47
36 x 12 Ak 2.75	CFM	825	1100	1375	1650	1925	2200	2750	3300
	Horizontal Throw	31-18	36-25	41-28	44-30	48-33	51-35	57-39	63-43
	Noise Criteria	-	-	21	27	31	35	42	47

Terminal Velocity of 75 and 150 FPM, respectively

NOTES:

1. Total Pressure in inches water column.
2. Throw data are in feet at terminal velocities of 75 and 150 FPM, respectively.
3. Noise Criteria based on a 10 dB room attenuation (Re: 10⁻¹² watts).