



CORE

- Two tough plies consisting of a layer of metalized polyester and a layer of clear polyester encapsulating a steel wire helix creating a high strength and durable product.
- Rated pressures (UL-181): 16 in. W.C. positive, 1 in. W.C. negative ($\leq 12''\phi$) & $1/2''$ W.C. negative ($> 12''\phi$).
- Recommended maximum operating pressures (ADC Test FD 72-R1):
6 in. w.g. positive for 12 in. diameter and under.
4 in. w.g. positive for 14 in. diameter and over.
- Rated maximum air velocity: 6000 FPM.

THERMAL CHARACTERISTICS

- R-8.0 formaldehyde free insulation certified by UL and the Air Diffusion Council in accordance with ADC Flexible Duct Performance and Installation Standards using ASTM C-518 at installed wall thickness on flat insulation only.

VAPOR BARRIER

- This metalized vapor barrier is constructed using fiberglass scrim which provides an outstanding combination of strength and tear resistance.
- Perm rating of 0.04 perms when measured per ASTM E96, Method A.

SURFACE BURNING CHARACTERISTICS

- Flame Spread: Less than 25
- Smoke Developed: Less than 50

OPERATING TEMPERATURE RANGE

- -20°F to 140°F Continuous
- -20°F to 250°F Intermittent

SIZE AVAILABILITY

- Standard length: 25 feet
- Diameters offered: 4" - 10", 12", 14", 16", 18" & 20"
- Plain ends

APPROVALS/COMPLIANCE

- UL-181 (UL LISTED)
- NFPA 90A & 90B
- HUD, IMC, UMC
- California Bureau of Home Furnishings
- Most Federal, State, and Local Codes and Standards.
- GREENGUARD Children & Schools
- GREENGUARD Level 4 "Highly Microbial Resistant" Rated
- CHPS
- American Schools & Hospital Facilities Product Directory

K:\User\Marketing\art Edgely\UL_CAS_RBL_Loop.jpg

JOB NAME: _____	SUBMITTED BY: _____	DATE: 7/17/2014	SD-5042
LOCATION: _____	F298, FB298 Insulated Flexible Air Duct, Class 1 R-8.0, Two Ply Metalized Polyester/Polyester Core Metalized Vapor Barrier		
ARCHITECT: _____			
ENGINEER: _____			
CONTRACTOR: _____			