

SUBMITTAL DRAWING

- EXTRUDED ALUMINUM CONSTRUCTION
- HINGES LOCATED AT BOTTOM ON WIDTH DIMENSION
- REMOVABLE FACE
- OPTIONAL FACE MOUNTING HOLES WITH SCREWS
- BARS ON 3/4 INCH CENTERS
- FILTER FRAME MAY BE SCREW FASTENED TO DUCT
- •USES NOMINAL 1 INCH FILTERS. SEE SD-9126-1 FOR 2-5" DEPTHS.
- FILTER SIZE EQUALS LISTED SIZE MINUS 1/4 INCH
- MINIMUM SIZE: 6 X 6
- MAXIMUM SIZE: 48 X 48 ONE PIECE CONSTRUCTION

