



SUBMITTAL DRAWING

- MATERIAL: .018 GALVANIZED STEEL
- NO. 3800 OR T-19 DAMPERS INSTALL DIRECTLY INTO PROVIDED COLLAR SLOTS
- BUILT IN BEAD FOR FLEX DUCT INSTALLATIONS
- A O.D. = DUCT SIZE MINUS 1/16
- PUSH CLIPS MOUNT THE COLLAR TO PRE-PUNCHED BACK PANEL HOLES
- SIZES AVAILABLE: 6, 8, 10, 12, 16 & 18 (14 INCH COLLAR FACTORY INSTALLED)





SECTION A-A

SIZE	A O.D.	
6	14	
8	14	
10	14	
12	14	
14	16	
16	20	
18	20	

NOTE:

THIS COLLAR CAN BE USED ON T-BAR PRODUCTS THAT HAVE A MOLDED FIBERGLASS BACK PANEL. ATTACHMENT REQUIRES THE USE OF THE 5400PP PUSH PINS.

JOB NAME:	SUBMITTED BY:	DATE: 08/05/2013	SD-9501
LOCATION:	5400 SERIES		
ARCHITECT:		Collar	
ENGINEER:			
CONTRACTOR:			